

Preliminary Assessment Report

Project 3021765, 8509 14TH AVE NW

Assessment Completed: 8/20/2015

Project Description: Construction of New SEDU Apartment in NC2-40 Zone within Crown Hill (Residential Urban Village) on 4,979 SF lot. Existing Single family residence to be removed.

Primary Applicant: [Robert Humble](#)

This report lists the results of a preliminary assessment of your project requirements by various city departments. It's based on the project characteristics described on your site plan and preliminary application form. If your project required a pre-application site visit (PASV), the results of that site visit are also included. The goal of this report is to help you create a complete submittal package and reduce the need for corrections once your application has been submitted.

Next Steps

1. Review the requirements in this report and contact the staff members listed below with questions.
2. If a street improvement plan is required, develop and submit it to the Seattle Department of Transportation (SDOT). **The Department of Planning and Development (DPD) will not accept your permit application until your street improvement plan is approved as 60% complete by SDOT. See [SDOT Client Assistance Memo 2213](#) for guidance about the 60% complete approval process.**
3. Schedule an appointment for permit application intake with DPD. **Please bring a copy of this report to your intake appointment.**

Questions About This Report

If you have questions about the information in this report, contact the appropriate city staff member for each section.

DPD Drainage Requirements

Matthew Bateman, (206) 615-1229, Matthew.Bateman@Seattle.gov

DPD Land Use Requirements

Branin Burdette, (206) 733-9694, branin.burdette@seattle.gov

DPD Preapplication Site Visit Requirements

Roxanne Kennedy, (206) 615-1283, Roxanne.Kennedy@seattle.gov

Seattle City Light Requirements

Ray Ramos, (206) 615-1193, ray.ramos@seattle.gov

Seattle Department of Transportation Requirements

Leo Kaarrekoski, leo.kaarrekoski@seattle.gov

Seattle Public Utilities Requirements

Steve Resnick, (206) 233-7234, ResnicS@seattle.gov

Water Availability

SPU Staff, (206) 684-3333, SPUWaterAvailability@Seattle.Gov

Other Resources

- General questions about the permit process: Contact the DPD Applicant Services Center (ASC) at 206-684-8850.
- User-friendly guides to city permitting processes: [DPD](#) and [SDOT](#).
- [Detailed zoning information](#).
- Visit our [permit type pages](#) for step-by-step instructions and forms for preparing your application and plans for review.

Requirements

DPD Drainage Requirements

The following requirements are based on the current stormwater and side sewer codes.

Existing Public Drainage Infrastructure

Sanitary sewer main location: 14th Ave NW

Sanitary sewer main size: 8"

Other location: 14th Ave NW (Culvert)

Other size: 12"

Drainage

The drainage point of discharge (SMC 22.805.020) is located at: Ditch or culvert. Culvert in 14th Ave NW

Flow Control Compliance

All new, replaced, and disturbed topsoil shall be amended with organic matter per rules promulgated by the Director prior to completion of the project to improve onsite management of drainage water flow and water quality per SMC 22.805.020.E. A completed [Construction Stormwater Control and Soil Amendment Standard Plan](#) is required.

Parcel-based projects with 7,000 square feet or more of land disturbing activity or 2,000 square feet or more of new plus replaced impervious surface must implement green stormwater infrastructure (bioretention cells, green roofs, permeable pavement, rainwater harvesting, etc.) to infiltrate, disperse, and retain drainage water onsite to the maximum extent feasible per SMC 22.805.020.F. and [Director's Rule 15-2012](#).

Flow control standards must be first met by utilizing green stormwater infrastructure to the maximum extent feasible. Additional flow control measures shall be installed if the flow control standard cannot be met solely using green stormwater infrastructure. Refer to [DR 17-2009](#). Submit a [Green Stormwater Requirement Calculator](#) along with additional flow control documentation.

For more information see: <http://www.seattle.gov/dpd/codesrules/codes/stormwater/default.htm>

This project site discharges to a Public Combined Sewer that is identified as a capacity-constrained conveyance system (SMC 805.050.A.6).

Based upon the information provided on the Preliminary Application Form, this project shall provide flow control meeting the Peak Flow Control Standard per SMC 22.805.080.B.4. The post-development peak flow with a 4% annual probability (25-year recurrence flow) shall not exceed 0.4 cubic feet per second per acre.

Additionally, the peak flow with a 50% annual probability (2-year recurrence flow) shall not exceed 0.15 cubic feet per second per acre. Projects with less than 10,000 sf new plus replaced impervious surface can use the [Pre-Sized Flow Control Calculator](#) in lieu of continuous modeling.

Water Quality

No requirements

Wastewater

All homeowners and building owners in King County's service area whose home or building was newly connected to the King County sewer system on or after Feb. 1, 1990 must pay a [King County Capacity Charge](#).

Permanent and Temporary Dewatering

The footing drain (if part of building plan) point of discharge ([DPD DR 4-2011](#)) is located at the following:
Ditch or culvert. Culvert in 14th Ave NW

Side Sewer

The existing side sewer for a new or converted building or dwelling unit may be reused pursuant to SMC 21.16.240.

In order to reuse an existing side sewer, the [Side Sewer Evaluation and Certification Form](#) must be completed by a licensed engineer.

DPD Land Use Code Requirements

Street Requirements

Based on the scope of the proposed project, the following street improvements are required per Chapter 23.53 of the Seattle Municipal Code. Please review Right-of-Way Improvements Manual for design criteria (<http://www.seattle.gov/transportation/rowmanual/manual/>). Show required street improvements on your "enhanced site plan" at DPD permit application intake. If an SDOT Street Improvement Plan (SIP) is required, please list SDOT project number and SDOT contact name on the enhanced site plan. Street Improvement Plans must be accepted by SDOT prior to DPD permit application intake.

14TH AVE NW

Curbs will be required to be installed in the portion of right-of-way abutting this lot.

A concrete sidewalk will be required to be installed in the portion of right-of-way abutting this lot.

Drainage may be required to be installed in the portion of right-of-way abutting this lot. Please contact SDOT for more information.

Street trees shall be provided in the planting strip according to Seattle Department of Transportation Tree Planting Standards. Contact SDOT Urban Forestry (for residential projects: (206) 684-TREE; for all others: (206) 684-5693), to determine species of tree and standards of planting. Please add a note to the site plan showing size, location and species of tree to be planted.

<http://www.seattle.gov/transportation/treeplanting.htm>.

Land Use

Based on the project scope and/or location of environmentally critical areas on the development site, SEPA may be required. See CAM 208 for more details.

Design Review is required; see CAM 238 for more details. Departures from development standards should be identified as early as possible in the application process.

An arborist report may be required. See CAM 242 for more detail.

Other Requirements

Based on the preliminary scope of the project, DPD recommends a presubmittal conference prior to submitting an application. Details for preparing and submitting a presubmittal conference request form can be found at our Web site (http://www.seattle.gov/dpd/Publications/Forms/Building_Permit/default.asp).

Since your development proposal includes alteration or demo of a 50+ year old structure, you are required to submit a "referral" to the Historic Preservation Program at Department of Neighborhoods (DON). DON staff will review the eligibility of the structure as a landmark. This determination must be made before you can schedule an intake appointment for your project.

Please see [Client Assistance Memo 3000](#) titled "DPD and DON Referral Process for Determining Landmark Eligibility" (pages 3-4). Your referral application should include a response to the "Appendix A of the Interdepartmental Agreement" on page 6 of the CAM. The referral information should be sent to "Karen Gordon, City Historic Preservation Officer, Department of Neighborhoods, PO Box 94649, Seattle, WA 98124".

Once the DON staff review the information contained in your referral, one of the following three determinations will be made:

- 1) The building appears to be ineligible as a landmark and no further Department of Neighborhoods review is required. You may schedule your intake appointment.
- 2) The subject building appears to be eligible and a Landmark Nomination application must be submitted to the DON Historic Preservation Program. This application and determination must occur before DPD permit intake since the outcome of this landmark nomination decision may affect the design or feasibility of your project.
- 3) The subject building/site is determined to be a designated City Landmark. A Certificate of Approval from the Landmarks Preservation Board is required for changes proposed to the designated features of the Landmark. You will need provide a copy of your application for a Landmark Certificate of Approval prior to permit intake. No DPD permit will not be issued until the Certificate of Approval has been issued.

Pre-Application Site Visit (PASV) Requirements

PASV report requirements may be subject to additions, changes, or modifications by the department. The purpose of the report is to alert the applicant that there may be unusual or complex site conditions that trigger requirements from the department regarding this project. **The applicant is responsible for providing all required documents at the intake appointment.** If you have questions about this report or the PASV process, please contact the DPD Site Development Team at (206) 684-8860.

Note: Any project application associated with the development site can utilize the results from this PASV if the application is accepted by DPD within 24 months of the above inspection date. After 24 months, the applicant must apply for another PASV. No extensions will be granted.

ECA Mapping Unit and Type

Non-ECA

Earth Disturbance

If excavation has the potential to encroach on adjacent property in order to facilitate construction activity, please provide documentation of consent from the adjacent property owner. Show area of proposed encroachment on the submitted drawings and detailed cross-sections.

If temporary cuts greater than 1h:1v will be required in order to facilitate construction activity, please provide a geotechnical engineer's verification that soil conditions allow cuts to stand unsupported. Include detailed cross sections.

Please show all existing and proposed retaining walls/rockeries and the exposed height.

If shoring will be required, please provide submittals by geotechnical and structural engineers and show the proposed system on the submitted drawings. Include detailed cross sections.

Existing ROW Conditions

14TH AVE NW

Street conditions:

Chip seal

Visible pavement width is: 27LF

Curb conditions:

No curb adjacent to site

A storm inlet is located <350 ft from the site and prior to crossing a public right of way.

Potential Impacts to Seattle Parks Property

No parks property in vicinity

Tree Protection

Trees greater than 6 inches in diameter as measured 4.5 ft above ground are present on the site but not shown on the site plan. Show the dripline of

- 1) **all** trees on the site,
- 2) adjacent trees that encroach on the site that are greater than 6 inches in diameter as measured 4.5 ft above ground, and
- 3) **all** trees located in the adjacent ROW.

Include common and scientific names for all trees shown. For more information, see [Director's Rule 16-2008](#) and [Tip 242](#).

Construction Stormwater Control

All projects with earth disturbance, regardless of size, require temporary and permanent stormwater control in accordance with the Construction Stormwater Control (CSC) Technical Requirements Manual ([DR 16-2009, Volume 2](#)).

Show the following on the [Construction Stormwater Control and Soil Amendment Standard Plan](#):

Place filter fabric, straw bales, straw wattles, or other approved equal to control construction stormwater runoff. Required along the following property lines:

Place compost socks, compost berms, filter fabric fencing, straw bales, straw wattles, or other approved perimeter control BMPs to eliminate construction stormwater runoff.

Show the location of a stabilized construction access to the site; show methods to eliminate uncontrolled conveyance of mud and dirt into the right of way (ROW).

Cover bare soil with compost blankets, straw, mulch, matting, or other approved equal to control construction stormwater runoff.

Cover stockpiles and bare slopes with compost blankets, tarps, matting or other approved equal to control construction stormwater runoff.

A First Ground Disturbance inspection is required before any ground disturbance related to this permit, including demolition, tree cutting, clearing, grubbing, and grading. After your permit is issued, schedule an inspection by calling (206) 684-8900 or [online](http://web1.seattle.gov/DPD/InspectionRequest/default.aspx) at <http://web1.seattle.gov/DPD/InspectionRequest/default.aspx>.

Seattle City Light Requirements

Conservation

Built Smart Programs - SCL offers developers of 5+ unit multifamily buildings incentives for installation of energy efficiency measures. From insulation and windows to lighting and appliances, take advantage of new technologies and construct a more efficient building with our help. For more information: contact Beth Rocha at (206)684-5945 or beth.rocha@seattle.gov.

Notes to Applicant

For new service, please contact the Electrical Service Representative for your area several months before new service is required to determine your electric service design, service location and what kind of service is available at the building site. An Application for Electrical Service must be submitted to Seattle City Light. The Electrical Service Representative should also be contacted to coordinate electrical disconnections prior to demolition and temporary power for construction. Your Electrical Service Representative is: Karen Quaife, 206-684-4983, karen.quaife@seattle.gov. Be advised that it is the applicant's responsibility to seek guidance from SCL. Failure to contact SCL early in the permit process could severely impact your project's scope, schedule and budget. This responsibility rests solely with the applicant.

SDOT Requirements

The City of Seattle's Right-of-Way Improvements Manual (ROWIM) and SDOT's Street & Sidewalk Pavement Opening and Restoration (PORR) Director's Rule 2004-02 may be accessed from SDOT's Street Use website at: http://www.seattle.gov/transportation/stuse_docs.htm. Whenever possible, specific reference notation for these two design documents is noted next to the design characteristics below. Be advised that these specific section and chapter references are provided as preliminary guidance only and are not comprehensive in scope.

SDOT Permitting Information

Initial Review Deposit: \$2,500

SDOT Plan Requirements: Engineered plan

SDOT Permit Requirements: Group 3: Street Use Major (Type 45). A 60% complete street improvement plan (SIP) must be approved by SDOT prior to your DPD construction intake appointment. SIP Design Guidance is required for 60% complete SIP approval; apply early. Please visit SDOT's Street Use website at: http://www.seattle.gov/transportation/stuse_sip.htm to obtain SDOT Client Assistance Memos (CAMs) and application materials to assist in developing your street improvement plan (SIP).

Street Improvement Requirements

14TH AVE NW

Tree planting. See Seattle Right of Way Improvements Manual (ROWIM) and City of Seattle Standard Plans 030, 100 and 424. Contact SDOT Urban Forestry for residential projects at (206) 684-TREE; for all others at (206) 684-5693 for approval of species and placement.

Roadway Widening: See Seattle Right of Way Improvements Manual (ROWIM) and the City's Standard Plans and Specifications.

New/replacement sidewalk: See Seattle Right of Way Improvements Manual (ROWIM) as well as the City of Seattle Standard Plan 420, 421 and 422.

New/Replacement Curb: See Seattle Right of Way Improvements Manual (ROWIM) and the City of Seattle Standard Plan 410.

New/replacement driveway: If there is a concrete curb in front of the project, the Street Use curb cut permit is issued by DPD. If there is not a concrete curb in front of the project, a Group 2 Street Use permit must be issued by Street Use. Refer to Standard Plan 430 for driveway curb cut standards.

SPU Requirements

Flow Control Compliance

All new, replaced, and disturbed topsoil shall be amended with organic matter per rules promulgated by the Director prior to completion of the project to improve onsite management of drainage water flow and water quality per SMC 22.805.020.E. For projects with 5,000 square feet or more of new and replaced impervious surface, a comprehensive drainage control plan shall be prepared by a licensed engineer.

All trail and sidewalk projects shall implement green stormwater infrastructure to the maximum extent feasible per SMC 22.805.030.

Water Availability

Your water availability assessment has been approved.
Water Availability Certificate reference number: 20151265
Water Availability Certificate status: Approved with No Changes
Prepared by: Clair LeFebre

Existing Water System Information

Proximity of nearest fire hydrant is: 246 feet SE of property. Meets standards.

Water Main:

Size: 8 inches	Material: Cast Iron	Class: 150
- Standard		
- Abutting		

Water Main is available to serve in: 14th Avenue NW

Distance of main to W margin of street is 40 feet.

Public ROW width is 60 feet.

Water Service(s):

Size: 3/4"	Material: Galvanized Iron
------------	---------------------------

Other Requirements

Owners of residential property occupied by a tenant who will be displaced by housing demolition, substantial rehabilitation, change of use, or removal of use restrictions may need to obtain a Tenant Relocation License. Refer to DPD Tip 123, Seattle's Tenant Relocation Assistance Ordinance, for further information and instructions or call (206) 684-7979.

If your project involves additions or modification to or demolition of an existing building that contains four or more dwelling units or 4,000 square feet or more of non-residential area, and the building is a designated historic landmark or is 50 years old and meets the criteria set forth in SMC 25.12 for landmark designation, SEPA is required. Please contact the Department of Neighborhoods at (206) 684-0228 or www.seattle.gov/neighborhoods/preservation to determine if your building is a designated landmark or if a referral is necessary to determine if the building meets the criteria in SMC 25.12. Refer to Tip 208 for information regarding the application requirements for a SEPA review and Tip 3000 for information regarding landmarks and historic preservation.

If the scope of your proposed project changes before your DPD intake appointment or SDOT street improvement plan application, the requirements in this report may change. If there are municipal code and ordinance changes before our DPD intake appointment, the project must meet the new code requirements. Additional street improvement requirements may be triggered if a permit application for a development project on adjacent property is also undergoing review.

Please be aware that all persons or companies working within the City limits, including all contractors, subcontractors, permit expeditors and other service providers are required to possess a valid City of Seattle business license. This license is required in addition to any other licenses required by the State of Washington, such as a contractors' license or state business license. For more information about City of Seattle business licenses, please contact inspector Michale Crooks at 206-684-8871, Michale.Crooks@seattle.gov, or visit the [Licensing and Tax Administration Division website](#).